



**DELHI JAL BOARD ; (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085**



**THE TEST REPORT IS
(ISO Certified 9001:2015) FOR THIS PARTICULAR
WATER SAMPLE ONLY**

Water sample collected from DJB stored water in the premises of Shri Ram Shiksha Mandir,
Senior Secondary School, Jindpur, Delhi -110036 vide challan no. 226 dated 14.11.2022.

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1
			Acceptable	Permissible	
1.	Date of collection	--	---	---	18.11.2022
2.	Date of Analysis	--	---	---	20.11.2022
3.	Colour	C.U.	5	15	<1 C.U.
4.	Odour	--	Agreeable		Agreeable
5.	Turbidity	N.T.U	1.0	5.0	1.12
6.	p ^H value	--	6.5 to 8.5	N.R.	7.5
7.	Electrical Conductivity	µmhos/cm	----	-----	1462.0
8.	Total Dissolved Solid	(mg/l)	500	2000	774.86
CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	(mg/l)	----	----	Nil
10.	Total Alkalinity	(mg/l)	200	600	169.0
11.	Total Hardness	(mg/l)	200	600	304.0
12.	Calcium Hardness	(mg/l)	200	600	189.0
13.	Magnesium Hardness	(mg/l)	200	600	115.0
14.	Calcium as Ca	(mg/l)	75	200	758.6
15.	Magnesium as mg	(mg/l)	30	100	27.6
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND
18.	Nitrate (NO ₃)	(mg/l)	45	N.R.	1.73
19.	Sulphate (SO ₄)	(mg/l)	200	400	95.27
20.	Chloride (Cl)	(mg/l)	250	1000	245.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.06
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.91
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	*N.D.
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.50
BACTERIOLOGICAL EXAMINATION					
25.	Coli form per 100 ml at 37°C	MPN/100 mL	0	0	0

*N.D. - Not Detectable

Remarks: On the basis of above tested parameters, water sample (S1) confirms to drinking water specification I.S.10500:2012 in permissible limit and may be used for drinking purpose.

[Signature]
Asstt. Chemist 20/11/22

[Signature]
Chemist/Bacteriologist 23/11/22

[Signature]
A.C.W.A. (HP- I)

[Signature]
C.W.A. (W&S)-II